



LENGTH OF THE RISER AT 45 DEGREES (IN FEET) "L"	VERTICAL DEPTH TO LATERAL AT CLEAN-OUT (IN FEET) "D"	TEST PRESSURES MINIMUM OF 4 PSI (IN PSI) SEE NOTE # 1
1	0.7	0.7
2	1.4	1.4
3	2.1	2.1
4	2.8	2.8
5	3.5	3.5
6	4.2	4.2
7	4.9	4.9
8	5.7	5.7
9	6.4	6.4
10	7.1	7.1
11	7.8	7.8
12	8.5	8.5
13	9.2	9.2
14	9.9	9.9
15	10.6	10.6
16	11.3	11.3

NOTE:

1. GROUND WATER IS ASSUMED AT 3'-0" BELOW GRADE.



**SEWER LATERAL TEST (AIR)
CITY ORDINANCE #1329**

DEPARTMENT OF PUBLIC WORKS

APPROVED BY

DATE

8/17/2006

DRAWING NO.

SS-2
(4 of 4)