



STREET OR ALLEY AREA

- 1a. BUILDING MUST HAVE CITY CLEAN-OUT IN RIGHT-OF-WAY AREA, OR OWNER MUST INSTALL NEW CITY CLEANOUT.
- 1b. CITY REPLACES "P" TRAPS IN RIGHT-OF-WAY ONLY.
2. TO PERFORM TEST, DOUBLE PLUG IS REQUIRED BY OWNER/CONTRACTOR.
3. AFTER TEST, CITY WILL LISTEN FOR WATER FROM TEST FIXTURE WHEN PLUG IS REMOVED TO CONFIRM LINE IS OPEN AND NOT PLUGGED ELSEWHERE.

TEST PROCEDURE

- ALTERNATE 1 -
- 1a. USE LOWEST FIXTURE WHICH IS A MINIMUM OF 2' ABOVE THE LATERAL ELEVATION AT CLEAN-OUT
 - 1b. CHECK THE BASEMENT DRAINS OR SUMP PUMP.
 - 1c. REMOVE AND PLUG ALL ILLEGAL CONNECTIONS (i.e. ROOF DRAINS AND SUMP PUMP.)
 2. FILL FIXTURE UNTIL WATER DOES NOT DRAIN.
 3. MARK WATER LEVEL.
 4. SHUT OFF BUILDING WATER SERVICE DURING CITY INSPECTION TEST.
 5. WAIT 30 MINUTES AND REFILL TO MARK.
 6. TEST PASSES IF WATER REFILLED IS FOUR (4) OR LESS GALLONS FOR FOUR (4") INCH OR SIX (6") INCH LATERAL.
- ALTERNATE 2 -
1. INSTALL OR USE EXISTING CLEAN-OUT OR FIXTURE AT THE FOUNDATION LEVEL (FLOOR JOIST LEVEL) OR SLAB FLOOR LEVEL.I.
 2. CONTINUE TEST AS IN ALTERNATE 1.