



STANDARD TRENCH SECTION

N.T.S.

REQUIREMENTS FOR TRENCH SECTION:

1. CONTRACTOR SHALL PLACE MINIMUM 6" CLASS 1 PERMEABLE BEDDING IF SOIL UNDERNEATH THE PIPE IS WET.
2. IF USED, CDF SHALL BE NO MORE THAN 1-1/2 SACK CEMENT.
3. BACKFILL MATERIAL SHALL BE CLASS 2 AGGREGATE BASE WITH 95% RELATIVE COMPACTION.
4. CONTRACTOR SHALL REPLACE ASPHALT CONCRETE AS SPECIFIED ABOVE OR MATCH EXISTING PAVEMENT SECTION (ASPHALT CONCRETE) WHICHEVER IS GREATER.
5. CONTRACTOR SHALL USE 1/2" ASPHALT CONCRETE ON THE EXPOSED SURFACE OF PAVEMENT.
6. TRENCH WIDTH SHALL BE MINIMUM OF 8" WIDER ON EACH SIDE OF THE PIPE PLUS THE DIAMETER OF THE PIPE.
7. FOR TREE ROOTS THAT ARE 2" (INCHES) OR MORE IN DIAMETER INSIDE THE TREE DRIP LINE, PLEASE CONTACT PARK DEPARTMENT AT (650) 558-7300 FOR INSPECTION PRIOR TO CUTTING THE ROOTS.
8. FOR CALIFORNIA DRIVE, BAYSHORE HIGHWAY, AND ROLLINS ROAD. PLACE MINIMUM 14" AC OR MATCH EXISTING PAVEMENT SECTION, WHICHEVER IS GREATER.



**TYPICAL SANITARY SEWER AND WATER
TRENCH SECTION**

DEPARTMENT OF PUBLIC WORKS

APPROVED BY

DATE

04/16/2014

DRAWING
NO.

G-10